

**Declaration of Conformity according to EN 13141-7:2004 / EN308**

**Technical Sciences**  
Laan van Westenenk 501  
7334 DT Apeldoorn  
Postbus 342  
7300 AH Apeldoorn

[www.tno.nl](http://www.tno.nl)

T +31 88 866 22 12  
F +31 88 866 22 48  
[infodesk@tno.nl](mailto:infodesk@tno.nl)

**TNO 2012 M10384A**

Determination of the energetic efficiency  
of the energy recovery appliance  
“Renovent Sky 300”  
Test report in accordance with  
EN 13141-7:2004 / EN308

Date	May 2013
Author(s)	H.A.J. Hammink
Sponsor	Brink Climate Systems BV R.D. Bügelstraat 3 7951 DA Staphorst
Project number	060.01122
Keywords	heat recovery efficiency

All rights reserved.

No part of this publication may be reproduced and/or published by print, photoprint, microfilm or any other means without the previous written consent of TNO.

In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the General Terms and Conditions for commissions to TNO, or the relevant agreement concluded between the contracting parties. Submitting the report for inspection to parties who have a direct interest is permitted.

© 2013 TNO

## Declaration of Conformity according to EN 13141-7:2004 / EN308

On behalf of Brink Climate Systems B.V., located in Staphorst, the Netherlands, the determination of the energetic efficiency was carried out by TNO Technical Sciences in Apeldoorn, the Netherlands.

Testing was performed according to:

- EN13141-7:2004 Performance testing of mechanical supply- and exhaust air ventilation units for single-family dwellings
- EN308, heat exchangers – Test procedures for establishing performance of air to air and flue gases heat recovery devices.

Key data for the tested unit:

Manufacturer:	Brink Climate Systems B.V.
Type	Renovent Sky 300
Serial number:	422004121601
Year of construction:	2012
CE approval:	Yes
Max. air flow	300 m <sup>3</sup> /h

Results for the energetic efficiency:

Air flow [m <sup>3</sup> /h]	Corrected $\eta_{temp}$	Power [W]	Voltage [V]	Current [A]	Power factor [-]
50	95.9	12.8	230.4	0.15	0.37
175	86.3	31.5	230.4	0.37	0.37
300	81.6	109.4	230.3	0.99	0.48

Date : 1 May 2013



Place : Apeldoorn  
Signed :  
Drs. P.M. van Hoorik  
Research Manager Energy and Comfort Systems

Measurement results, leak tightness classification, fan characteristics and the functioning of the energy recovery appliance at low temperatures are given in short report TNO 2012 M10384, July 2012.